

#26410

PERMIT INSTRUCT
INSTALL OR MODIFY SMALL WASTEWATER FACILITY

BOOK NO. 562

Cheyenne-Laramie Co. Health Unit
Div. of Environmental Health
1710 Snyder Avenue
Cheyenne, WY 82001
307-771-0665 Fax: 771-3665

PERMIT NO. 2768

Legal: R 64 T 14 Sec 22

Property Address: 7192 Co Rd 140

Size of Lot 320 ac +/- Slope _____

Lot/Tract _____ Block _____

Owner: John Kaufman

Subdivision _____

Address PO Box 126 Ph: 547-3436

Well installed: Yes: No:

Town / City Hillsdale Zip 82060

Well to Septic Tank (50' min.): 120 ft.

Installer / Contractor Ken Trakell

Well to final disposal (100' min.): 120 ft.

Type of Building Residence
(residence, trailer, other; gallon per day)

Soil type _____

Number of bedrooms: four (4)

Depth of sewer rock: _____
above pipe: 2" below pipe: 18"

Septic tank gallons 1000 gallon (1500)

Material (concrete) other Precast 2 compt

Secondary treatment Standard Trench
(trench, bed, other)

sq. ft. 320 width 24" lineal 185

sq. ft. _____ width _____ lineal 190'

REMARKS: _____

APPLICANT'S SIGNATURE: John Kaufman

I certify that the installation of the Small Wastewater Facility described in this permit will be in compliance with Minimum Standards for Small Wastewater Facilities.

Preliminary approval Henry M. Hickman Onsite 3/13 Date 3, 16, 92

Final approval Henry M. Hickman Date 3, 17, 92

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Laramie County Small Wastewater Facilities Regulations have been met. The County or the City-County Health Unit assumes no liability for, and does not in any way guarantee the performance of any Small Wastewater Facility.

WHITE COPY—Environmental Health; YELLOW COPY—Applicant; BLUE COPY—County Zoning Office

This diagram is for office use only.
It is not to scale & it's accuracy is not guaranteed.


**"NOT TO BE USED"
FOR THE CONVEYANCE
OF PROPERTY**

no home

This diagram is for office use only. It is not to scale & it's accuracy is not guaranteed.

1500 gallon
3 1/2" riser inlet
3" riser outlet

well house



**"NOT TO BE USED"
FOR THE CONVEYANCE
OF PROPERTY**

This diagram is for office use only. It is not to scale & it's accuracy is not guaranteed.

**"NOT TO BE USED"
FOR THE CONVEYANCE
OF PROPERTY**

Co Rd 140